


Laboratory Report**ENDYNE Inc.**
Environmental Laboratories

South Georgia Fire District 100509
73 Sunset Circle
Milton, VT 05468
Atten: Jeffrey Vance

PROJECT: WSID 5121 TC

WORK ORDER: 2408-24155

DATE RECEIVED: August 06, 2024

DATE REPORTED: August 07, 2024

SAMPLER: Jeffrey Vance

VT0005121

001 Site: Kitchen Sink 558 Cedarwood Terrace

Date Sampled: 8/6/24 Time: 8:55

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual
Total Coliform	ABSENT	/100 mL	SM 9223B (-16)	8/6/24 10:57	W EPB	A	HSNOTE
E. coli	ABSENT	/100 mL	SM 9223B (-16)	8/6/24 10:57	W EPB	A	

HSNOTE: Your sample container was overfilled. Our accrediting authority has asked that we reject these samples or perform a transfer step that would require additional expense. We have performed that transfer step this initial time but please be aware that in the future you MAY be charged a fee. Please review the sampling procedures and ask us if you have questions.

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director

www.endynelabs.com

160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

ELAP 11263

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893



NH2037