


Laboratory Report**ENDYNE Inc.**
Environmental Laboratories

South Georgia Fire District 100509
73 Sunset Circle
Milton, VT 05468
Atten: Jeffrey Vance

PROJECT: WSID 5121 TC
WORK ORDER: 2411-36141
DATE RECEIVED: November 04, 2024
DATE REPORTED: November 05, 2024
SAMPLER: Jeffrey Vance

VT0005121

001 Site: Kitchen Sink 211 Heritage Drive Date Sampled: 11/4/24 Time: 9:55

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: RT Compl Ind: Y Repl Ind: N

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Total Coliform	ABSENT	/100mL	SM 9223B (-16)	11/4/24 14:01	W EPB	A	
E. coli	ABSENT	/100mL	SM 9223B (-16)	11/4/24 14:01	W EPB	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director



160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

www.endynelabs.com

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893

